

## FIRE SAFETY CERTIFICATE

No.: 213/24

Dated: 11.06.2024

Certified that the GITANJALI PUBLIC SCHOOL at Vill – Daikota, P.O. – Deriapur, P.S. – Sainthia, Dist. – Birbhum, PIN– 731234, West Bengal comprised of basement(s) and G2 (upper floors) owned/occupied by GITANJALI PUBLIC SCHOOL run by GITANJALI FOUNDATION have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 8.06.2024 in the presence of RAIHAN UL HAQUE, at Vill – Daikota, P.O. – Deriapur, P.S. Sainthia; Dist. – Birbhum, PIN– 731234, West Bengal and that the building/premises is fit for occupancy up to classes I to XII further applied for renewal for fire NOC vide AIN no. 221191240630000058 dated 05.04.2024 and same was renewed up to 10.06.2027.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the driveway.
2. The interior finish decoration of the building shall be made low flame spread materials: conforming I.S. specifications.
3. To eliminate the risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
6. Mock Fire practice and evacuation drill shall be performed periodically with the participation of all occupants of the building.
7. Transformer and switch gear room shall be protected with automatic CO2 or DCP fire extinguisher conforming I.S. specification.
8. First aid firefighting system shall be provided as per I.S. specification.
9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
10. Fire License shall have to be obtained for storing and processing with highly combustible articles.
11. The issuance of Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.
12. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Renewal of Fire Safety Certificate will be treated as cancelled.

Issued on 11.06.2024 at West Bengal Fire & Emergency Services, Lalkhuti Para, Suri, Birbhum, Pin: 731101 by

Signature with Seal:

*Partha Sarathi Ghosh*  
 Station Officer  
 Name: Partha Sarathi Ghosh  
 Designation: Fire Station Officer  
 Name & Address of Department/Office:  
West Bengal Fire & Emergency Services  
Lalkhuti Para, Suri, Birbhum, Pin: 731101

To,  
GITANJALI PUBLIC SCHOOL  
Vill – Daikota, P.O. – Deriapur,  
P.S. – Sainthia, Dist. – Birbhum,  
Pin – 731234, West Bengal

Validity: 10.06.2027

*Raihan ul Haque*  
 Manager,  
 Gitanjali Public School

*Principal*  
 Gitanjali Public School

